



APPLICATIONS NOTICE

temperzone limited
Auckland, NEW ZEALAND.
Phone 0-9-279 5250, Fax 0-9-275 5637
Email sales@temperzone.co.nz

temperzone australia Pty Ltd
Sydney, AUSTRALIA.
Phone (02) 9671 5055, Fax (02) 9622 3154
Email sales@temperzone.com.au

Form NS 006

TO: AUTHORISED DEALERS/DISTRIBUTORS ISSUE NO. : 02/01
 N.Z. APPROVED INSTALLERS
 H.O., REG'L & AUST. MANAGERS DATE : 11 January 2001
 APPLIC. NOTICE GENERAL LIST FROM : T King/K Edwards

SUBJECT: HANWEST CONTROLS APPLIED TO TEMPERZONE UNITS

UNITS: All Split & Packaged Air Cooled Units

Attached is a data sheet 1896 (09/00) showing the wiring requirements when connecting HANWEST Controllers to temperzone Split System Units. The diagrams on the data sheet refer to split units but diagrams Fig. 2 and Fig. 6 can equally be applied to OPA units. Use Fig. 2 for OPA101, 150 & 180, and Fig. 6 for OPA210-920.

Please note that each diagram also details which links should and should not be removed to suit the control voltage and fan motor voltage.

For further information relating to remote sensors, averaging sensors or any other special requirement, refer the HanWest Data and Installation Sheets for connections and dip switch setting changes.