



Remote Input/Output



Default Inputs (Open/Closed)

1. Fix into heating: CN1 (1+2)
2. Fix into cooling: CN1 (2+3)
3. Demand Stoppage (0% Capacity): CN2 (1+2)



Default Outputs (12V DC)

1. Operation: CN7 (1+2)
2. Alarm: CN7 (2+3)



Other Inputs Available (Requires Programming)

- | | |
|------------------------------|------------------------------|
| A. Forced Stoppage | (All Stop) |
| B. Demand (capacity) Control | 40% / 60% / 70% / 80% / 100% |

Other Outputs Available (Requires Programming)

- A. Compressor On
- B. Defrost

Plug Required

PCC-1A (171-000-241)

